

## Q&A Consistency Meeting Agenda for Plumbing, March 2017

1. Question: Can the product, BoneDry, be used to seal the space between the pipe and a sleeve through a foundation wall?

Answer: After researching the product, there is an ICC Evaluation. The evaluation refers to the product as a membrane material, to only be installed on parged and non-parged masonry walls. In the Evaluation, it refers back to local code for penetrations. The product has not been evaluated to seal penetrations, therefore we would be unable to accept it for that use.

2. Question: Are toilet flanges required to be installed during the rough inspection?

Answer: No, while many contractors have them installed during the rough inspection, some do not. Some use this for their stand pipe to perform the water test. Others want to wait as the final decision on the flooring has not been made.

3. Question: Can a mop sink/canwash be built custom using tile and shower pan liner? If so, does it need to be tested?

Answer: We can find no standard for mop sinks, therefore we see no reason one cannot be constructed using the same techniques used to build custom showers. Testing would be required the same as a shower, as this would be field fabricated.

4. Question: Can a floor drain used to drain a pool go to storm if the pool is a saltwater pool?

Answer: No, pool drains and backwash are not allowed to go to storm.